

**BS7671:2022 TABLE 4E1A - Single-core 90°C thermosetting insulated cables, non-armoured, with or without sheath (COPPER CONDUCTORS)**

Conductor cross-sectional area	Reference Method A (enclosed in conduit in thermally insulating wall etc.)		Reference Method B (enclosed in conduit on a wall or in trunking etc.)		Reference Method C (clipped direct)		Reference Method F (in free air or on a perforated cable tray etc horizontal or vertical etc) Touching			Reference Method G (in free air) Spaced by one cable diameter		
	2 cables, single-phase AC or DC	3 or 4 cables, three-phase AC	2 cables, single-phase AC or DC	3 or 4 cables, three-phase AC	2 cables, single-phase AC or DC flat and touching	3 or 4 cables, three-phase AC flat and touching or trefoil	2 cables, single-phase AC or DC flat	3 cables, three-phase AC flat	3 cables, three-phase AC trefoil	2 cables, single-phase AC or DC or 3 cables three-phase AC flat		
	2	3	4	5	6	7	8	9	10	Horizontal	Vertical	
1	2	3	4	5	6	7	8	9	10	11	12	
(mm <sup>2</sup> )	(A)	(A)	(A)	(A)	(A)	(A)	(A)	(A)	(A)	(A)	(A)	(A)
1	14	13	17	15	19	17.5	-	-	-	-	-	-
1.5	19	17	23	20	25	23	-	-	-	-	-	-
2.5	26	23	31	28	34	31	-	-	-	-	-	-
4	35	31	42	37	46	41	-	-	-	-	-	-
6	45	40	54	48	59	54	-	-	-	-	-	-
10	61	54	75	66	81	74	-	-	-	-	-	-
16	81	73	100	88	109	99	-	-	-	-	-	-
25	106	95	133	117	143	130	161	141	135	182	161	
35	131	117	164	144	176	161	200	176	169	226	201	
50	158	141	198	175	228	209	242	216	207	275	246	
70	200	179	253	222	293	268	310	279	268	353	318	
95	241	216	306	269	355	326	377	342	328	430	389	
120	278	249	354	312	413	379	437	400	383	500	454	
150	318	285	393	342	476	436	504	464	444	577	527	
185	362	324	449	384	545	500	575	533	510	661	605	
240	424	380	528	450	644	590	679	634	607	781	719	
300	486	435	603	514	743	681	783	736	703	902	833	
400	-	-	683	584	868	793	940	868	823	1085	1008	

**Notes**

- 1) Where it is intended to connect the cables in this table to equipment or accessories designed to operate at a temperature lower than the maximum operating temperature of the cable, the cables should be rated at the maximum operating temperature of the equipment or accessory(see BS7671 Regulation 512.1.5).
- 2) Where it is intended to group a cable in this table with other cables, the cable should be rated at the lowest of the maximum operating temperatures of any of the cables in the group (See BS7671 Regulation 512.1.5).
- 3) **For cables having flexible conductors see BS7671:2022 Appendix 3 section 2.4 for adjustment factors for current-carrying capacity and voltage drop.**